

Maintenance Report July 2012

Goodwood Main Library

Sealed Roof at Back of Building
Completed Lighting Preventive Maintenance on First Floor

Carver Branch Library

Completing Lighting Preventive Maintenance

Central Branch Library

In Process of Repairing Boiler
Ordered Replacement Energy Management Controls

Greenwell Springs Road Regional Branch Library

Completed Replacement of 1,024 Light Bulbs
As a Result of Brown Out Replaced 10 Motor Starters that Control Air Conditioner

Pride-Chaneyville Branch Library

Completed Chiller Repair, Replacing a Low Pressure Switch and Contactor

Recycled Reads

Added Two Light Fixtures in Hall

Scotlandville Branch Library

Replaced Some Emergency Lighting Fixtures

Zachary Branch Library

Completed Repairs on 3 out of 6 Fans on Chiller
Ordered Compressor for Chiller