

Maintenance Report April 2012

All Branches

Started Preventative Maintenance on all A/C Equipment
Condenser Barrels on All Water Cooled Machines and All Condenser Coils on Air Cooled Machines Cleaned
All Energy Managements Audits Completed

Baker Branch Library

Energy Management Audit Completed

Central Branch Library

Energy Management Audit Completed
Energy Management Adjustments Being Made Based on The Energy Management Audit

Greenwell Springs Road Regional Branch Library

Energy Management Audit Completed
Performing General Maintenance on the Energy Management System

Jones Creek Regional Branch Library

All Interior Lighting Finished
Installing Taller Pole Lights with LED's to Parking Lot with a Payback Around 6 Years
Raised Poles to Provide More Light Coverage and Additional Measure of Security to Parking Lot

Scotlandville Branch Library

Energy Management Audit Completed