

---

## WHLC Architecture - Schwartz/Silver Architects

---

A Joint Venture

### CONSTRUCTION REPORT

---

Project: River Center Branch Library

Project No.: 11-025

Report No.: 021

Site Visit Date/Time: 10-12-2017

Location: Project Site; site visit and walk

Attendees: R. Roussel, T. Colomb, T. Mathis, M. Caillouet

Weather/Temp: Sunny, Partly Cloudy, Hot and Humid.

#### Work in Progress/Observations:

- ACM panel mockup was installed on the South-East radius section
- The liquid applied vapor permeable membrane is still on going.
- Interior framing is ongoing.
- Interior rough-in work is ongoing.
- There is spray foam insulation being installed at both cantilevered overhangs. It's being installed direction on to the spray-applied fire proofing.
- Storefront framing is being installed throughout the project as well.
- Interior framing work continues
- Roofing work is ongoing at the high section of the roof.
- Vapor barrier work is still in progress at the high sections of the 4th floor structure.
- The framing for the reveal is being started now as well.
- The storefront framing material is on site.
- The structural knife plates still need to be framed around, sheathed and vapor barrier applied.

(see attached photos)

Items/Questions:

Prepared by: WHLC Architecture, LLC.



IMG\_6609



IMG\_6611



IMG\_6617



IMG\_6620



IMG\_6622



IMG\_6623



IMG\_6624